



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2022861
Permit # 00307-2021UPG
Request Rec'd 03/15/2021
Amended Date
Approval Date 3/15/2021 DS
Permit Expires 9/15/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Graham Enterprise, Inc. 750 Bunker Court Vernon Hills, IL 60061</p> <p>Contact: John Graham (847) 837-0777</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Wilmette BP SS#285 840 Skokie Boulevard Wilmette, IL 60091</p> <p>Contact: Margarita Buruiana (847) 251-4321</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 8, 10) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 8, 10) - Gasoline - Regular*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 8, 10) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 8, 10) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replacing existing Fill riser inside a non-regulated sump w/ FiberTite MultiPort Fill manhole w/ 5 gal SW OPW buckets on RUL #1 & PUL.
Replacing the existing coaxial Overfill valves on RUL#1 & PUL with OPW 61 SOP poppeted coaxial overfill valves.

NOTE: The existing N.O.V. was satisfied with the passing test results being submitted on 3/1/21


(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
Performance Tank, Inc. 730 Creel Drive	Contact Person: Tim Berg

Wood Dale, IL 60191

Phone: (630) 860-9500

Contractor Registration # IL881 Exp. 12/8/2022

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File