



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1044503
Permit # 00312-2021UPG
Request Rec'd 03/17/2021
Amended Date
Approval Date 3/17/2021 DS
Permit Expires 9/17/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Kelley Williamson Company 1132 Harrison Avenue Rockford, IL 61104 Contact: Bob Sanders (815) 397-9410	(2) FACILITY - name and address where tanks are located: Loves Park Mobil 6232 N. 2nd Street Loves Park, IL 61111 Contact: Leslie Alverson (815) 637-0535
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000, (TK # 2, 3, 4) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Gasoline - Mid-grade, (TK # 3) - Gasoline - Premium, (TK # 4) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices: (TK # 1, 2, 3, 4) Overfill Prev Device - Ball Float Vent Valve*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) SPECIAL CONTINGENCIES** : Removed ball floats and using alarm as form of overfill protection.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 4/12/2022

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File