



**City of Chicago**  
**Department of Public Health**  
 333 South State Street, Room 200  
 Chicago, IL 60604  
 3127453162

<p><b>FOR OFFICE USE ONLY</b></p> <p>Facility # 2042062          Permit # 00324-2021REM          Request Rec'd 03/19/2021          Amended Date          Approval Date 3/19/2021          Permit Expires 9/21/2021</p>
--

**Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>City of Chicago Department of Fleet and Facility Management          30 North LaSalle Street, Suite 300          Chicago, IL 60602</p> <p>Contact: Curtis Anderson (312) 747-4950</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>FS004 Southwest          3746 S. Iron St.          Chicago, IL 60609</p> <p>Contact: Rich Kroth (312) 744-8174</p>
---	--

**(3) REMOVAL OF PIPING:**


- (a) Description/location of piping being removed:*
- (b) Which tank(s) are associated with the piping being removed: (TK # 1, 2, 3, 4) - 20,000*
- (c) Reason of piping being removed:*
- (d) If piping is leaking, indicate IEMA incident number:*

**(4)** After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

**(5) SPECIAL CONTINGENCIES :**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>K-Plus Mechanical, Inc.          10220 Bode Street Suite A          Plainfield, IL 605851631</p>	<p>Contact Person: Gerald Ford          Phone: (815) 230-3040          Contractor Registration # IL002335 Exp. 2/9/2022</p>

Sincerely,

  
 Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist  
 Division File