



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Amended**

<p align="center"><b>FOR OFFICE USE ONLY</b></p> <p>Facility # 1007421 Permit # 00174-2021UPG Request Rec'd 02/11/2021 Amended Date 03/22/2021 DS Approval Date 2/15/2021 DS Permit Expires 8/17/2021</p>
---

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>A Z Green, LLC 4962 20th Street Rockford, IL 61109 Contact: Anjun Abdul (815) 873-0505</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>AZ Green, LLC 4962 South 20th Street Rockford, IL 61109 Contact: Abdul Anjum (815) 873-0505</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 4) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 4) Piping - Shear Valves, (TK # 4) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 4) - Gasoline - Regular*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Replace flex connector and shear valve beneath dispenser 5/6. Perform a post construction precision line test  
Amendment Reason: Leaking flex connector beneath 5/6, not 11/12.


**NOTE: A dispenser sump must be installed if one doesn't already exist**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Stenstrom Petroleum Services Group	Contact Person: Robert Stenstrom

2422 Center Street  
Rockford, IL 61108

Phone: (815) 398-6250  
Contractor Registration # IL1890 Exp. 4/12/2022

Sincerely,

  
\_\_\_\_\_

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File