



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 6013703  
Permit # 00344-2021UPG  
Request Rec'd 03/23/2021  
Amended Date  
Approval Date 3/23/2021 DS  
Permit Expires 9/23/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Lowell's Service Center, LLC 2000 Vandalia Street Collinsville, IL 62234</p> <p>Contact: Greg Lowell (618) 344-3312</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Lowell's Service Center 2000 Vandalia Street Collinsville, IL 62234</p> <p>Contact: Greg Lowell (618) 344-3312</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 5) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 5) - Gasoline - Premium*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices: (TK # 5) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

New OPV drop tube installed after Ball float was untestable

**NOTE: Ball float must be removed or disabled**


**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Superior Acquisition LLC d/b/a Superior Equipment Company  
7525-A Sussex

Contact Person: Matt Gross  
Phone: (314) 644-6000  
Contractor Registration # IL002394 Exp. 3/8/2023

St. Louis, MO 63143

Sincerely,



---

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File