



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2025081
Permit # 00349-2021UPG
Request Rec'd 03/24/2021
Amended Date
Approval Date 3/24/2021 DS
Permit Expires 9/24/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

| | |
|--|---|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Nomani Estate, LLC 3935 Main Street Skokie, IL 60076 Contact: (847) 571-5053</p> | <p>(2) FACILITY - name and address where tanks are located:</p> <p>Nomani Estate, LLC d/b/a Amstar 13800 S. Halsted St. Riverdale, IL 60827 Contact: Umair Nomani (847) 571-5053</p> |
|--|---|

(3) **UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 4,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 5) Piping - Flexible Double Wall NUPI Smartflex from tank to dispensers as shown in site plan, (TK # 5) Piping - Other Submersible Pump, (TK # 5) Piping - Single Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 5) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank: (TK # 5) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350*
 - Piping: (TK # 5) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 5) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in submersible and dispenser sumps*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 5) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 5) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES :**

Tank top upgrade. All new Singlewall containment sumps. Spill buckets, risers, drop tubes. Doublewall NUPI Smartflex piping. Diesel only as shown on attached drawings.

Replaced piping exceeds 20 feet or 50% of the total pipe run.


NOTE: A removal permit must be submitted for piping

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Cardinal Compliance LLC
730 Creel Dr
Wood Dale, IL 601910000

Contact Person: Chris Derro
Phone: (708) 452-8620
Contractor Registration # IL002418 Exp. 3/18/2023

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in black ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File