



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 3127453162

| |
|---|
| <p><u>FOR OFFICE USE ONLY</u> Facility # 2013029 Permit # 00384-2021REM Request Rec'd 03/31/2021 Amended Date Approval Date 3/31/2021 Permit Expires 9/30/2021</p> |
|---|

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

| | |
|--|---|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: 3115 Properties, LLC 778 W. Frontage Rd., Suite 124 Northfield, IL 60093 Contact: John Mengels (847) 441-9797</p> | <p>(2) FACILITY - name and address where tanks are located: 3115 Properties, LLC 3115 N Broadway Chicago, IL 60657 Contact: Lewandowski Frank (847) 441-9797</p> |
|--|---|

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed: (TK # 4) - 1,000*
- (b) Description/location of piping being removed:*
- (c) Product to be stored in each tank: (TK # 4) - Gasoline - Regular*
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used: (TK # 4) - 12/31/1973*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

| | |
|--|--|
| (6) PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| RW Collins Company 7225 West 66th Street Chicago, IL 60638 | Contact Person: Lisa Kruse Phone: (708) 458-6868 Contractor Registration # IL772 Exp. 2/9/2022 |

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
 Division File