



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2013539
Permit # 00011-2021UPG
Request Rec'd 01/06/2021
Amended Date 04/05/2021 DS
Approval Date 1/6/2021 DS
Permit Expires 7/7/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Hadi Inc. 8204 West 47th Street Lyons, IL 60534</p> <p>Contact: Fouzia Hussain (708) 447-7320</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Bob John's Citgo 8204 West 47Th Street Lyons, IL 60534</p> <p>Contact: Shahid Hussain (630) 202-1646</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 6, 7) - 8,000, (TK # 13) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 6) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L vor vents, (TK # 6) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from tank to dispenser as shown in site plan, (TK # 6) Piping - Other Submersible Pump, (TK # 6) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 6) - Diesel Fuel, (TK # 7) - Gasoline - Premium, (TK # 13) - Gasoline - Regular*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 6) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices: (TK # 6) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replaced piping exceeds 20 feet or 50% of the total pipe run.

Amendment Reason: Change in the piping layout and re did all the ventline and changed spill buckets too


Revision Reason: Added note about needing removal permit for piping

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

America Petropump Services LLC d/b/a Ampsco Services
4075 Fox Valley Center Dr., Unit 9
Aurora, IL 60504

Contact Person: Kiran Patibandla
Phone: (630) 649-8699
Contractor Registration # IL002420 Exp. 5/22/2021

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File