



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2008986
Permit # 00391-2021UPG
Request Rec'd 04/02/2021
Amended Date
Approval Date 4/5/2021 DS
Permit Expires 10/5/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Buchanan Energy (N), LLC 7315 Mercy Road Omaha, NE 68124 Contact: Kelly Bissias (312) 636-1323	(2) <u>FACILITY</u> - name and address where tanks are located: Ektaa Enterprises Inc. dba Deerfield Mobil 650 Waukegan Road Deerfield, IL 60015 Contact: Mukesh Bhatia (630) 660-6854
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 7) - 500*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 7) - Used Oil*

(e) *Type of leak detection being used:*

Tank: (TK # 7) Leak Detect - Tank - 110 - 600 gallons Manual Tank Gauging

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Change tank leak detection method from CSLD to Manual Tank Gauging

NOTE: Existing NOV has been satisfied

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: (815) 398-6250

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", written in dark ink on a light background. The signature is fluid and stylized, with the first name "Daniel" and last name "Starks" clearly legible. The middle initial "H." is smaller and less distinct. The signature is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File