



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2033566
Permit # 01691-2020UPG
Request Rec'd 11/25/2020
Amended Date 04/05/2021 DS
Approval Date 11/25/2020 DS
Permit Expires 5/25/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Commonwealth Edison/Exelon Corporation 3 Lincoln Center - Real Estate & Facilities Oakbrook Terrace, IL 601814260 Contact: Michael Grazioli (630) 303-2681</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Corporate Computer Center 1700 Spencer Road Joliet, IL 604338569 Contact: Josh Walter (630) 688-4409</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 20,000, (TK # 3) - 1,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 1, 2) Piping - Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping, (TK # 1, 2) Piping - Anti-siphon Valves OPW 99ASV-2200, (TK # 1, 2) Piping - Valves Foot Valve, (TK # 1, 2, 3) Piping - Double Wall STP/Tanktop Sump, (TK # 1, 2) Piping - Double Wall Transition Sump, (TK # 3) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX*

(d) *Product to be stored in each tank: (TK # 1, 2) - Diesel Fuel, (TK # 3) - Used Oil*

(e) *Type of leak detection being used:*

Tank: (TK # 3) Leak Detect - Tank - Non-Discriminating Sensors Interstitial Monitoring

Piping: (TK # 1) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 1, 2) Leak Detect - Piping - Discriminating Sump Sensor, (TK # 2) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection, (TK # 3) Leak Detect - Piping - Non-Discriminating Sump Sensor

(f) *Corrosion Protection being used:*

Tank:

Piping: (TK # 1, 2) Corrosion Prot - Piping - Fiberglass Non-Corrosive

(g) *Spill containment devices, piping, and dispenser containment devices: (TK # 1, 2) Spill Contain Device - Single Wall Spill Bucket*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replaced piping exceeds 20 feet or 50% of the total pipe run.

Amendment Reason: Removal of existing single wall sump and upgrading to a double wall sump on the waste oil tank.


NOTE: A removal permit must be obtained to remove old piping

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

MZI Group, Inc.
1937 W Fulton St
Chicago, IL 60612

Contact Person: Raul Romero
Phone: (312) 492-8740
Contractor Registration # IL002447 Exp. 5/7/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel S. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File