



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2038918
Permit # 00510-2021UPG
Request Rec'd 04/23/2021
Amended Date
Approval Date 4/26/2021 DS
Permit Expires 10/26/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Naperville Excavating 1805 High Grove Lane Naperville, IL 60540</p> <p>Contact: Brian Doll (630) 355-8094</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Naperville Excavating 1805 High Grove Lane Naperville, IL 60540</p> <p>Contact: Brian Doll (Skippy) (630) 355-8094</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2, 3) Piping - Fiberglass Single Wall Piping*
- (d) Product to be stored in each tank: (TK # 1, 2) - Diesel Fuel, (TK # 3) - Gasoline - Regular*
- (e) Type of leak detection being used:*
 - Tank: (TK # 1, 2, 3) Leak Detect - Tank - Automatic Tank Gauging Franklin Fueling Systems EVO 200*
 - Piping: (TK # 1, 2, 3) Leak Detect - Piping - European with No Test Req Suction*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Removing existing STP's and product piping under removal permit. Removing section of existing island for new dispenser sumps. Installing new fiberglass 2" piping European suction with new fiberglass dispenser sumps. Replacing existing Auto Stic tank monitoring system with new Franklin EVO 200 tank monitoring system. Layout of existing site will be the same. Converting site from a pressure system to European suction. New Gas Boy suction pumps to be installed with checks under pumps only.


Replaced piping exceeds 20 feet or 50% of the total pipe run.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Howard Lee & Sons Inc.
4093 Perryville Road PO Box 446
Cherry Valley, IL 61016

Contact Person: Vicky Buhl
Phone: (815) 332-4966
Contractor Registration # IL456 Exp. 3/20/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File