

## City of Chicago Department of Public Health

333 South State Street, Room 200 Chicago, IL 60604 3127453162

## **FOR OFFICE USE ONLY**

Facility # 2039409 Permit # 00509-2021INS Request Rec'd 04/24/2021 Amended Date Approval Date 4/27/2021 Permit Expires 10/27/2021

## Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.** 

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:

Anthony Marano Co., Inc

1501 S Blue Island Ave Chicago, IL 606082213

Contact: Jody Or Anton Marano (312) 829-5055

(2) FACILITY - name and address where tanks are located:

Marano Market 2820 S Ashland Ave Chicago, IL 60608

Contact: Peter Helle (312) 829-9426

## (3) <u>INSTALLATION OF TANKS:</u>

- (a) Number and size of tanks being installed: (TK # 3) 12,000, (TK # 4) 4,000
- (b) Type of tank(s): (TK # 3, 4) Tank Fiberglass Double Wall XERXES
- (c) Type of piping: (TK # 3, 4) Piping Fiberglass Double Wall Ameron Dualoy 3000/LCX
- (d) Product to be stored in each tank: (TK # 3) Diesel Fuel, (TK # 4) Gasoline Regular
- (e) Type of leak detection being used:
  - Tank: (TK # 3, 4) Leak Detect Tank Automatic Tank Gauging Veeder Root TLS 450 Plus, (TK # 3, 4) Leak Detect Tank Non-Discriminating Interstitial Monitoring Sensors
  - Piping: (TK # 3, 4) Leak Detect Piping Electronic Pressurized Line Leak Detection, (TK # 3, 4) Leak Detect Piping Non-Discriminating Sump Sensor, (TK # 3, 4, 4) Leak Detect Piping Non-Discriminating Sump Sensor with positive shutdown
- (f) Corrosion Protection being used:

Tank: (TK # 3, 4) Corrosion Prot - Tank - Fiberglass Non-Corrosive

Piping: (TK # 3, 4) Corrosion Prot - Piping - Fiberglass Non-Corrosive

- (g) Spill containment devices, piping and dispenser containment devices: (TK # 3, 4) Spill Contain Device Single Wall Spill Bucket
- (h) Overfill prevention devices: (TK # 3, 4) Overfill Prev Device Overfill Drop Tube Valve
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.govor by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS: There shall be a minimum of two manufactured slotted or perforated observation wells of at lease 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

## (6) SPECIAL CONTINGENCIES:

# (6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Petroleum Technologies Equipment, Inc. 8447 West 44th Place Lyons, IL 60534

Contact Person: Thomas Doherty Phone: (708) 426-0400

Contractor Registration # IL2051 Exp. 1/17/2022

Sincerely,

Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist Division File