



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 7023240
Permit # 00368-2021REM
Request Rec'd 03/28/2021
Amended Date 04/28/2021 DS
Approval Date 3/29/2021 DS
Permit Expires 9/29/2021

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Phillip & Doris Hodges 111 Washington Street Cairo, IL 62914 Contact: Philip Hodges (618) 559-5097	(2) <u>FACILITY</u> - name and address where tanks are located: Fill Up Mart 477 S. Blanche Street Mounds, IL 62964 Contact: Doris Hodges (618) 358-2581
--	--

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed: (TK # 1, 2, 4) - 6,000, (TK # 3) - 2,000, (TK # 5) - 1,000, (TK # 6) - 560*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1, 2, 5) - Gasoline - Regular, (TK # 3) - Diesel Fuel, (TK # 4) - Gasoline - Premium, (TK # 6) - Heating Oil*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number: 2021-0271*
- (f) *Date each tank was last used: (TK # 1, 2, 3, 4) - 3/3/2020, (TK # 5, 6) - Unknown*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

remove entire ust system, tanks and piping

Amendment Reason: additional tanks found

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

RCRA, Inc. d/b/a Earth Services
10903 Prestwick Drive
Benton, IL 62812

Contact Person: Josh Appleton
Phone: (618) 218-4958
Contractor Registration # IL002364 Exp. 8/7/2021

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File