



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 7011098
Permit # 00537-2021UPG
Request Rec'd 04/30/2021
Amended Date
Approval Date 5/3/2021 DS
Permit Expires 11/3/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>DAR Kinkaid Investors, Inc. 2063 Marina Rd. Murphysboro, IL 62966 Contact: Agan President Alkan (573) 979-3111</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Kinkaid Marina 2063 Marina Road Murphysboro, IL 62966 Contact: Agan Alkan (618) 687-4914</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 3) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 3) Piping - Other Submersible Pump, (TK # 3) Piping - Positive Shutoff Valves, (TK # 3) Piping - Single Wall STP/Tanktop Sump, (TK # 3) Piping - Single Wall Transition Sump*
- (d) Product to be stored in each tank: (TK # 3) - Gasoline - Non Ethanol*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 3) Leak Detect - Piping - Non-Discriminating Sump Sensor*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Removed dispensers from the dock, blow fuel out of the lines.
Removed dispenser sumps, Tank Sump and both transition sumps.
Install new dispenser sumps, transition sumps & tanks sump/sub motor.
Install entry boots, solenoid valve and reconnect piping at the sump pump and dispenser sumps.
Install breakaway valve at the transition sump on land. Re-connect all piping
Perform air test with OSFM.
Backfill & pour concrete.


Get all sumps sensors operational and test.
Set dispensers back in place.
Purge the lines and perform a line and leak detector test.
Perform sump test, ATG operability test, Spill bucket & overfill valve test.
Perform Final Inspection with OSFM.
Will perform a like for like permit if the spill bucket, overfill fail the test.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Mid-South Steel Products, Inc.
2071 Corporate Circle Drive PO Box 277
Cape Girardeau, MO 63703

Contact Person: Billy Thorne
Phone: (573) 335-5529
Contractor Registration # IL1194 Exp. 8/17/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File