



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Amended**

**FOR OFFICE USE ONLY**

Facility # 6017347  
Permit # 00515-2021UPG  
Request Rec'd 04/27/2021  
Amended Date 05/04/2021 DS  
Approval Date 4/27/2021 DS  
Permit Expires 10/27/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Jai Ganeshay, Inc. 1257 Lebanon Avenue Belleville, IL 62221</p> <p>Contact: T J Patel (618) 567-0080</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>BP Food Shop 1257 Lebanon Avenue Belleville, IL 62221</p> <p>Contact: Manager (618) 567-0080</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 7) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 7) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L, (TK # 7) Piping - Steel Single Wall Piping, (TK # 7) Piping - Other Steel Riser, (TK # 7) Piping - Other Submersible Pump, (TK # 7) Piping - Ball Valves, (TK # 7) Piping - Flex Connector Steel, (TK # 7) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 7) - Gasoline - Mid-grade*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

The existing submerged pump has a bad 4" riser pipe. Remove the existing STP. Install a new STP sump in the same location (middle tank) and modify the existing single wall product piping as needed for the sump installation. Install different submerged pump, Install new flex connector, ball valve and steel piping to connect the STP.

Amendment Reason: When I filled out the permit, I did not realize there were two RUL tanks. The Mid Grade tank is shown, so our work was actually done on the tank that is listed here as the Mid Grade tank and not the UL tank.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

UPC Enterprises, LC d/b/a United Petroleum Service  
4444 Union Blvd.  
St. Louis, MO 63115

Contact Person: Terry Smith  
Phone: (314) 241-3767  
Contractor Registration # IL002402 Exp. 2/10/2022

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File