



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 3000813
Permit # 00579-2021UPG
Request Rec'd 05/11/2021
Amended Date 05/17/2021 DS
Approval Date 5/11/2021 DS
Permit Expires 11/12/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Guraya, Inc. 1009 Division Street Orion, IL 61273 Contact: Harbhajan Singh (309) 314-3707</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Alpha Mart Phillips 66 202 S. 1st Street Alpha, IL 61413 Contact: Inderjeet Victor (309) 529-2225</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 1) - Gasoline - Regular*
- (e) Type of leak detection being used:*
Tank:
Piping:
- (f) Corrosion Protection being used:*
Tank:
Piping:
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Amendment Reason: The concrete will be cut outside of the dispenser sump. CPEC will excavate to the product line depth, cut the product line, install a new Bell x Male fitting and a new connector. Originally we were going to change the connector inside the dispenser sump but will be unable to do so. Thank you.


NOTE: The existing sump must still be used as containment and piping cannot bypass it

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
Central Petroleum Equipment Company	Contact Person: Roger Clark

109 Terrace Dr.
Blue Grass, IA 52726

Phone: (563) 381-5092
Contractor Registration # IL345 Exp. 6/14/2022

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File