



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2000258  
Permit # 00591-2021UPG  
Request Rec'd 05/14/2021  
Amended Date  
Approval Date 5/17/2021 DS  
Permit Expires 11/17/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Midlothian Amstar, Inc. 14506 S. Pulaski Rd. Midlothian, IL 60445 Contact: (708) 597-9414</p>	<p>(2) <b>FACILITY</b> - name and address where tanks are located:</p> <p>Midlothian Amstar, Inc. 14506 S. Pulaski Rd. Midlothian, IL 60445 Contact: Imitiaz Memon (708) 597-9414</p>
---	---

(3) **UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1) Piping - Other Steel Riser*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 1) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 1) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES :**

<p>(6) <b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448</p>	<p>Contact Person: Ronald Anderson Phone: (708) 478-6190 Contractor Registration # IL002275 Exp. 5/21/2022</p>

Sincerely,

*Daniel G. Starks*

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File