



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2047253
Permit # 00637-2021REM
Request Rec'd 05/26/2021
Amended Date
Approval Date 5/27/2021 SB
Permit Expires 11/30/2021

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>2233 WEST STREET llv 2233 West North ST River Grove, IL 60171</p> <p>Contact: Greg Rzedzian (773) 843-1400</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>2233 WEST STREET LLC 9700 W. Waveland AV 3700 N. Rose AV Schiller Park, IL 60131</p> <p>Contact: George Kobylarcik (708) 341-3160</p>
---	--

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed: (TK # 1) - 8,000, (TK # 2) - 6,000*
- (b) Description/location of piping being removed:*
- (c) Product to be stored in each tank: (TK # 1) - #2 Fuel Oil, (TK # 2) - Diesel Fuel*
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used: (TK # 1, 2) - 12/31/1973*

- (4)** The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

Excavate to expose top of tank. Remove caps and pump liquids from tank. Ckeck LEL in tank, if 5% or less continue, if greater than 5% vent or inert tank. Re-check LEL or % O2 if tank is inerted. If 5% or less continue if not vent or inert until 5% or less LEL or O2 is reached. Excavate to free tank and hoist tank from excavation. place tank on poly. Re-check LEL or % O2 if 5% or less continue if not vent or inert until 5% isw reached. Cut opening(s) in tank. Use non sparking tools. Clean tank interior, place tank scrapings in durm. Hoist tank with back hoe and place on trailor and transport to scrap yard.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Environmental Protection Industries, Inc.
16650 South Canal Street
South Holland, IL 60473

Contact Person: Eryn Barba
Phone: (708) 225-1115
Contractor Registration # IL564 Exp. 6/27/2022

Sincerely,

Shelly Bradley

Shelly Bradley

cc: Storage Tank Safety Specialist
Division File