



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 4045469
Permit # 00665-2021UPG
Request Rec'd 06/02/2021
Amended Date
Approval Date 6/2/2021 DS
Permit Expires 12/2/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Kroger Limited Partnership I 5960 Castleway West Drive Indianapolis, IN 46250</p> <p>Contact: Harley Ruger (317) 710-1212</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Kroger Fuel Center #J-946 4615 East US 36 Decatur, IL 61521</p> <p>Contact: Christina Cobren (217) 864-5073</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 8,000, (TK # 2) - 10,000, (TK # 3) - 20,000*
 - (b) Type of tanks:*
 - (c) Type of piping:*
 - (d) Product to be stored in each tank: (TK # 1) - Gasoline - Premium, (TK # 2) - Diesel Fuel, (TK # 3) - Gasoline - Regular*
 - (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
 - (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
 - (g) Spill containment devices, piping, and dispenser containment devices: (TK # 1, 2, 3) Spill Contain Device - Single Wall Spill Bucket*
 - (h) Overfill prevention devices:*
 - (i) Manway accessible at grade:*
- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES** : Removing multiport spill containers and sump sensors. Installing flex boots over flex connectors. Drilling holes in bottom of sumps to allow water to drain. Filling sumps with pea gravel and pouring concrete.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554	Contact Person: Chris Epkins Phone: (309) 347-1819 Contractor Registration # IL1293 Exp. 2/4/2022

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File