



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2047248
Permit # 00672-2021REM
Request Rec'd 06/03/2021
Amended Date
Approval Date 6/3/2021 DS
Permit Expires 12/3/2021

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Oak Park Madison Street, LLC 4333 S. Pulaski Rd Chicago, IL 60632 Contact: (773) 843-1400</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Oak Park Madison Street LLC 640-660 W. Madison Street Oak Park, IL 60302 Contact: (773) 843-1400</p>
--	---

(3) **REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 2, 3) - 4,000, (TK # 4, 5) - 1,500, (TK # 8) - 6,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 2, 3, 8) - Heating Oil, (TK # 4, 5) - Unknown*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 2, 3, 4, 5, 8) - 12/31/1973*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES :**

Remove five (5) underground storage tanks (USTs). Utilize vacuum truck to pump out any residual product /liquid remaining in tanks. Excavate to expose top of tanks. Ground/bond tanks. Vent or inert tanks. Check LEL or O2, when <5%, excavate to expose tanks. Lift tanks with crane or back-hoe. Place tanks on poly. Re-check LEL/O2, when <5% cut opening(s) in tanks using non-sparking tools. Clean tanks/drum tank scrapings. Place tanks on trailer and haul to scrap yard.

NOTE: All associated piping must be removed as well

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Environmental Protection Industries, Inc.
16650 South Canal Street
South Holland, IL 60473

Contact Person: Eryn Barba
Phone: (708) 225-1115
Contractor Registration # IL564 Exp. 6/27/2022

Sincerely,

Daniel Starks

Division File