



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 5019361
Permit # 00694-2021UPG
Request Rec'd 06/08/2021
Amended Date
Approval Date 6/9/2021 DS
Permit Expires 12/9/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>GPM Investments, LLC 8565 Magellan Pkwy, Suite 400 Richmond, VA 23227</p> <p>Contact: Chad Fluck (804) 730-1563</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Jiffi Stop #574 804 W. Quincy, Rt. 96 North Pleasant Hill, IL 62366</p> <p>Contact: Rolfe Lann (804) 730-1568</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 4) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 4) Piping - Steel Single Wall Piping , (TK # 4) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 4) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) SPECIAL CONTINGENCIES** : DIESEL PUMP HIT AND BROKE THE SHEAR VALVE. INSTALLING NEW ISLAND DISPENSER SUMP with new impact valve and flex connector. we are putting this on single wall steel pipe.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

R. L. Hoener Company
2923 Gardner Expressway P. O. Box 1086
Quincy, IL 62305

Contact Person: Marty Jackson
Phone: (217) 223-2190
Contractor Registration # IL2021 Exp. 5/22/2022

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File