



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

**Amended**

FOR OFFICE USE ONLY  
Facility # 2-007981  
Permit # 01558-2007UPG  
Request Rec'd 09/25/2007  
**Amended Date 10/04/2007**  
Approval Date 9/27/2007 JC  
Permit Expires 3/27/2008

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Gas City, Ltd. 160 S. LaGrange Road Frankfort, IL 60423  Contact: Len McEnergy (815) 469-9000	<b>(2) FACILITY</b> - name and address where tanks are located:  Petro 5915 Monee Rd,I-57 & Monee Rd Monee, Will Co., IL  Contact: Len McEnergy (815) 469-9000
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired:* (TK # 3, 4) - 20,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 3, 4) - (Installing) Ameron Dualoy 3000/LCX double wall fiberglass piping to accommodate the manifolding of the piping at the tank sump area.

(d) *Product to be stored in each tank:* (TK # 3, 4) - Diesel Fuel

(e) *Type of leak detection being used:*

*Tank:*

*Piping:* (TK # 3) - (Installing) Red Jacket FX1V mechanical line leak detector, (TK # 3, 4) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at both tank sumps only

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>          Contact Person: Mark Romiti Phone: (630) 530-9880  Contractor Registration #    Exp.
--

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 1/98)