

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY

Facility # 4-007142
Permit # 01621-2007INS
Request Rec'd 10/03/2007
Amended Date
Approval Date 10/3/2007 JC
Permit Expires 4/3/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Tri-Star Marketing, Inc. 2211 W. Bradley, P.O. Box 9279 Champaign, IL 61826-9279	Super Pantry 10 1212 N. Bowman Danville, Vermilion Co., IL
Contact: Kathy Delsignore (217) 367-8387 Ext. 133	Contact: Chuck Cline (217) 367-8386

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: One compartment tank consisting of: (TK # 7, 8) 5,000 gallons each
- (b) Type of tanks: (TK # 7, 8) (Installing) Containment Solutions double wall fiberglass brine filled
- (c) Type of piping: (TK # 7, 8) (Installing) Ameron Dualoy 3000/LCX double wall fiberglass
- (d) Product to be stored in each tank: (TK # 7) E-85, (TK # 8) Diesel Fuel
- (e) Type of leak detection being used:

Tank: (TK # 7, 8) - Existing automatic tank gauging to be used from the existing tank system. New probes will be installed for inventory purposes only, (TK # 7, 8) - (Installing) Veeder Root TLS 350 hydrostatic reservoir sensor for leak detection.

Piping: (TK # 7) - (Installing) Red Jacket FX1V mechanical line leak detector, (TK # 7, 8) - (Installing) Veeder Root TLS350 interstitial piping sump sensors as follows: (E-85 at the submersible sump and at the dispenser sump will have a 794380-430, and the diesel submersible sump will have a 794380-208), (TK # 8) - (Installing) Veeder Root Wireless pressurized electronic line leak detector. Tanks 7 & 8 share the same dispenser island.

(f) Corrosion Protection being used:

Tank: (TK # 7, 8) - (Installing) Fiberglass **Piping:** (TK # 7, 8) - (Installing) Fiberglass

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) **GENERAL REQUIREMENTS:**
- (6) **SPECIAL CONTINGENCIES**:

(7) PERSON, FIRM OR COMPANY PERFORMING WORK:		
	Contact Person: Phone:	
	Contractor Registration # IL-1293	Exp.

Sincerely,

James of Coffey