



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 6-015245
Permit # 01601-2007REL
Request Rec'd 10/02/2007
Amended Date
Approval Date 10/2/2007 DS
Permit Expires 4/2/2008

**Permit for INTERIOR LINING of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to internally line underground storage tank(s) or piping is hereby granted. Such interior lining must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. Such interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          SNC JJ Centralia, LLC          2101 S. Banker Street, P.O. Box 250          Effingham, IL 62401          Contact:</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Jumpin Jimmy's          617 W. Broadway          Centralia, Marion Co., IL          Contact: Linda Niebrugge (217) 342-2205</p>
---	---

**(3) INTERIOR LINING OF TANKS:**

- (a) *Number and size of tanks being internally lined:* (TK # 1) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Name of manufacturer of internal lining material:* (TK # 1) Armor Shield
- (d) *Designation of internal lining material:* (TK # 1) TL 300M
- (e) *Product to be stored in each tank:* (TK # 1) - Gasoline  
 (Internal lining material must be compatible with product stored in each tank)
- (f) *Manway accessible at grade:* No

**(4) This permit is VOID if tank is unacceptable for interior lining. Any tank that has been out of service for a twelve month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for interior lining and manway installation only. Separate permits are required to do interior tank lining inspections.**

**(5) The owner must notify this Office when completion of tank internal lining has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(6) SPECIAL CONTINGENCIES:** Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by sections 170.430(a)(1)(C) and (D), 170.430(b)(5), and 170.430(c)(10).

<b>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Bolin Enterprises, Inc.	Contact Person: Phone: Contractor Registration #    Exp.

Sincerely,

*Daniel G. Starks*

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 1/98)