



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 2-020667
Permit # 01226-2012LIN
Request Rec'd 11/21/2012
Amended Date
Approval Date 11/21/2012 DS
Permit Expires 5/21/2013

Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Parts 174, 175 and 176. Such inspections of interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Lake Bluff Petroleum, Inc. 218 N. Waukegan Road Lake Bluff, IL 60044 Contact: Manny Joseph	(2) FACILITY - name and address where tanks are located: Lake Bluff Petroleum, Inc. 218 N. Waukegan Rd. Lake Bluff, Lake Co., IL Contact: Manny Joseph
--	---

(3) INSPECTION OF INTERIOR LINING OF TANKS:

(a) *Number and size of tanks being inspected:* (TK # 1) - 10,000 gallons, (TK # 2, 3) - 6,000 gallons

(b) *Type of tanks:*

(c) *Product stored in each tank:* (TK # 1, 2, 3) - Gasoline

(d) *Manway accessible at grade:* Yes


(4) Any tank that has been out of service for a twelve-month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for the inspection of the existing interior lining only. No repairing, upgrading, or interior lining is authorized with this permit.

(5) The owner must notify this Office when completion of tank interior inspection has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(6) **SPECIAL CONTINGENCIES:** Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by section 175.500.

(7) PERSON, FIRM OR COMPANY PERFORMING WORK: MPC Construction, Inc. 921 West 8th Street Minonk, IL 61760	Contact Person: Brian McCormick Phone: (309) 208-5264 Contractor Registration # Exp.
--	---

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)