



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 7011747  
Permit # 00736-2021UPG  
Request Rec'd 06/23/2021  
Amended Date  
Approval Date 6/23/2021 DS  
Permit Expires 12/23/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

|  |   |
|--|---|
| <p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>2 James, LLC<br/>5850 Hwy 145<br/>Harrisburg IL 62946<br/><br/>Contact: Mike Duncan (618) 694-9060</p> | <p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Mitchellville Country Store<br/>5850 Highway 145 South<br/>Harrisburg IL 62946<br/><br/>Contact: Mike Duncan (618) 252-6414</p> |
|--|---|

**(3) UPGRADE OR REPAIR OF TANKS:**


- (a) Number and size of tanks being upgraded or repaired: (TK # 8) - 30,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 8) - Diesel Fuel*
- (e) Type of leak detection being used:*  
*Tank:*  
*Piping: (TK # 8) Leak Detect - Piping - Electronic Pressurized Line Leak Detection*
- (f) Corrosion Protection being used:*  
*Tank:*  
*Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Tank 8 has two submerged pumps and the lines are manifolded together. The way the lines are manifolded and both submerged pumps come on together means the submerged pump without a leak detector will operate even if the leak detector senses a leak. We will install another electronic line leak detector into the pump without one and then change the submerged pumps to alternate and run one pump at a time.

|   |   |
|---|---|
| <b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>   |   |
| UPC Enterprises, LC d/b/a United Petroleum Service<br>4444 Union Blvd.<br>St. Louis, MO 63115 | Contact Person: Terry Smith<br>Phone: (314) 241-3767<br>Contractor Registration # IL002402 Exp. 2/10/2022 |

Sincerely,

  
\_\_\_\_\_

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File