



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2022802
Permit # 00737-2021UPG
Request Rec'd 06/23/2021
Amended Date 06/28/2021 DS
Approval Date 6/23/2021 DS
Permit Expires 7/7/2021

**Permit for Emergency Repair Request on 6/19/2021
Amended**

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

| | |
|---|---|
| <p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Graham Enterprise, Inc. 750 Bunker Court Vernon Hills, IL 60061 Contact: John Graham (847) 837-0777</p> | <p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>BP Highland Park (SS# 278) 695 Central Avenue Highland Park, IL 60035 Contact: Mohamed Oiuuld Sidi Mohamed (847) 433-1866</p> |
|---|---|

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 8, 9, 10) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 8, 9, 10) Piping - Flexible Single Wall Piping , (TK # 8, 9, 10) Piping - Steel Single Wall Piping*
- (d) Product to be stored in each tank: (TK # 8, 9) - Gasoline - Regular, (TK # 10) - Gasoline - Premium*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :


Amendment Reason: Upon exposing leak in Premium line, we discovered 3- Gas Lines (Tanks #8,9,10) had ball valves in line, direct buried. We removed all and replaced with section of NUPI Smartflex piping as noted for repair made on Tank #10 under this permit. All lines have been Third Party Tested.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Cardinal Compliance LLC
730 Creel Dr

Contact Person: Chris Derro
Phone: (708) 452-8620

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File