



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 2041981
Permit # 00761-2021UPG
Request Rec'd 06/29/2021
Amended Date
Approval Date 6/29/2021 DS
Permit Expires 12/29/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Ahmad Zahdan 12345 S. Keeler Ave. Alsip, IL 60803</p> <p>Contact: Ahmad Zahdan (708) 372-7632</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Quest BP, Inc. 322 W. 14th Street (W. Lincoln Hwy) Chicago Heights, IL 60411</p> <p>Contact: Bilal Muaref (312) 835-1744</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 12,000, (TK # 2) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2) Piping - Flexible Double Wall A.P.T. Poly Tech XP 1500 from tanks to all dispensers as shown in site plan, (TK # 1, 2) Piping - Other Steel Riser, (TK # 1, 2) Piping - Ball Valves, (TK # 1, 2) Piping - Positive Shutoff Valves, (TK # 1, 2) Piping - Shear Valves, (TK # 1, 2) Piping - Flex Connector Steel, (TK # 1, 2) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Gasoline - Premium*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Replacing all sumps, piping, and islands to resolve NOV E0020210967.

Replaced piping exceeds 20 feet or 50% of the total pipe run.


**NOTES: Site has existing sump sensors but they must be wired for positive shut down if not already. A removal permit MUST be obtained for the removal of existing piping ASAP**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

B & K Equipment Company  
2939 175th Street  
Lansing, IL 60438

Contact Person: Ed Angell  
Phone: (708) 474-3344  
Contractor Registration # IL1207 Exp. 2/14/2022

Sincerely,

  
\_\_\_\_\_

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File