



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 4009542  
Permit # 00770-2021UPG  
Request Rec'd 06/30/2021  
Amended Date  
Approval Date 7/1/2021 DS  
Permit Expires 1/4/2022

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>HPT TA Properties, LLC 24601 Center Ridge Road Westlake, OH 44145</p> <p>Contact: Bonnie Parrino (440) 808-7268</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Effingham Travel Center 1702 West Evergreen I-57, I-70 &amp; 32/33, Exit 170 Effingham, IL 62401</p> <p>Contact: David Westenier (217) 347-7183</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 14, 15, 16, 17) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 14, 15, 16, 17) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from tanks to dispensers, (TK # 14, 15, 16, 17) Piping - Ball Valves, (TK # 14, 15, 16, 17) Piping - Flex Connector Steel, (TK # 14, 15, 16, 17) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 14, 15, 16, 17) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 14, 15, 16, 17) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection, (TK # 14, 15, 16, 17) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in submersible and dispenser sumps*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Replace all piping with LCX double wall pipe system with submerge pump sumps with sump sensors positive shut down. This in addition of B99 permit work. Permit was requested by Travis Smith to get paper work correct.

Replaced piping exceeds 20 feet or 50% of the total pipe run.

**NOTE: A removal permit has already been issued**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Petro Maintenance  
8766 E 1200th Ave. PO Box 194  
Robinson, IL 62454

Contact Person: John McKeighan  
Phone: (618) 544-7448  
Contractor Registration # IL725 Exp. 3/15/2022

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File