



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2027814  
Permit # 00775-2021UPG  
Request Rec'd 07/02/2021  
Amended Date  
Approval Date 7/6/2021 DS  
Permit Expires 1/6/2022

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Midwest Gas, Inc. 17845 Ridge Rd. Minooka, IL 60447 Contact: Dan (815) 467-4398</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Minooka Citgo, Inc. 17845 Ridge Road Minooka, IL 60447 Contact: Dan Siddiqui (630) 479-1529</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 12,000, (TK # 7) - 20,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 1, 7) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX*

(d) *Product to be stored in each tank: (TK # 1) - Diesel Fuel, (TK # 7) - Gasoline - Regular*

(e) *Type of leak detection being used:*

*Tank:*

*Piping:*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Convert existing Tank # 1 Diesel into Regular Unleaded via underground piping between submerge sumps and island.

Convert existing Tank # 7 Regular Unleaded into Diesel via underground piping between submerge sumps and island

See attached drawing

Will change Veeder Root probe floats and reprogram Veeder Root to new products and tank ID's

No work will be done inside of sump

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Stenstrom Petroleum Services Group  
2422 Center Street  
Rockford, IL 61108

Contact Person: Robert Stenstrom  
Phone: (815) 398-6250  
Contractor Registration # IL1890 Exp. 4/12/2022

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File