



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 1008456
Permit # 00792-2021UPG
Request Rec'd 07/09/2021
Amended Date
Approval Date 7/12/2021 DS
Permit Expires 1/12/2022

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Carroll Service Company 505 West Illinois Route 64 Lanark, IL 61046</p> <p>Contact: chris markley (815) 493-2181</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Carroll Service Company 505 West Illinois Route 64 Lanark, IL 61046</p> <p>Contact: Chris Markley (815) 493-2181</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 3) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 3) Piping - Flexible Double Wall A.P.T. Poly Tech as shown in site plan from existing dispenser to new satellite dispenser, (TK # 3) Piping - Shear Valves*
- (d) Product to be stored in each tank: (TK # 3) - Diesel Fuel*
- (e) Type of leak detection being used:*  
*Tank:*  
*Piping: (TK # 3) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in new dispenser sump*  
*NOTE: If dispenser sump that the new piping is starting from doesn't have a sensor in it then one must be installed*
- (f) Corrosion Protection being used:*  
*Tank:*  
*Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*


- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES :** New 3' x 5' x 9" stainless steel island forms to be installed under all dispensers. New satellite dispenser to be installed at location shown on plans. New SW fiberglass dispenser sump & non discriminating sensor to be installed under new satellite. Satellite line will be 1.5" APT DW flexible piping. New Gilbarco Encore 700 dispensers to be installed for the gas dispensers and diesel master dispenser. New Gilbarco Legacy dispensers to be installed for the existing satellite and new satellite. Existing canopy to remain.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>
---

Oil Equipment Company, Inc.  
4701 Lien Road  
Madison, WI 53704

Contact Person: TJ Winkler  
Phone: (608) 249-2881  
Contractor Registration # IL1318 Exp. 11/13/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in black ink and is positioned above a thin horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File