



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 2001747
Permit # 00795-2021UPG
Request Rec'd 07/12/2021
Amended Date
Approval Date 7/12/2021 DS
Permit Expires 1/12/2022

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Allied Waste Services 5050 West Lake Street Melrose Park, IL 60160</p> <p>Contact: Tom Lindemulder (708) 345-3055 Ext. 2186</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Allied Waste Services 4800 West Lake Street Melrose Park, IL 60160</p> <p>Contact: Tracy Smith (708) 345-3055 Ext. 2186</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 4) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 4) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 4) - Diesel Fuel*
- (e) Type of leak detection being used:*  
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*  
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Replacing the flex connector under Dispenser 1/2 in order to correct the height of the shear valve. This work will not affect any piping penetrations in the dispenser pan.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>Beacon SSI, Inc. 10526 W. Cermak Rd Suite 302 Westchester, IL 60154</p>	<p>Contact Person: Patrick Ferriter Phone: (708) 917-2263 Contractor Registration # IL002336 Exp. 1/27/2023</p>

Sincerely,

  
\_\_\_\_\_

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File