



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 2027155
Permit # 00820-2021UPG
Request Rec'd 07/19/2021
Amended Date
Approval Date 7/19/2021 DS
Permit Expires 1/19/2022

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Graham Enterprise, Inc. 750 Bunker Court Vernon Hills, IL 60061</p> <p>Contact: John Graham (847) 837-0777</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Forest View BP (GEI-164) 4701 S. Central Avenue Forest View, IL 60638</p> <p>Contact: Meghan Fitzpatrick (847) 837-0777</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 6) - 15,000, (TK # 7, 8) - 10,000, (TK # 9) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 6, 7, 8, 9) Piping - Flexible Double Wall NUPI Smartflex from existing tanks to dispensers as shown in site plan, (TK # 6, 7, 8, 9) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 6, 7) - Gasoline - Regular, (TK # 8) - Gasoline - Premium, (TK # 9) - Diesel Fuel*
- (e) Type of leak detection being used:*  
**Tank:**  
*Piping: (TK # 6, 7, 8, 9) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 6, 7, 8, 9) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in all submersible and dispenser sumps*
- (f) Corrosion Protection being used:*  
**Tank:**  
**Piping:**
- (g) Spill containment devices, piping, and dispenser containment devices: (TK # 6, 7, 8, 9) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 6, 7, 8, 9) Overfill Prev Device - Overfill Drop Tube Valve, (TK # 6, 7, 8, 9) Overfill Prev Device - Overfill Alarm*
- (i) Manway accessible at grade:*

**(4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

We will be converting the existing 15,000 gallon PUL to RUL, the existing 10,000 gallon RUL to PUL, the existing 10,000 gallon RUL to DSL and the existing 6,000 gallon DSL to E85. Installing new under dispenser sumps, STP sumps and new Nupi Smartflex product piping to (10) new islands. Installing new swfrtp fill sumps with new Nupi Smartflex remote fill piping to new Franklin Defender spill buckets, and new Nupi sw vent piping to parkway area as shown.

Replaced piping exceeds 20 feet or 50% of the total pipe run.


**NOTE: Change of products must be done under a notification form**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Performance Tank, Inc.  
730 Creel Drive  
Wood Dale, IL 60191

Contact Person: Tim Berg  
Phone: (630) 860-9500  
Contractor Registration # IL881 Exp. 12/8/2022

Sincerely,



*Daniel S. Starks*

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File