



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2010685
Permit # 00821-2021UPG
Request Rec'd 07/19/2021
Amended Date
Approval Date 7/19/2021 DS
Permit Expires 1/19/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Graham C-Stores Co. 39109 N. US Hwy 41 Wadsworth, IL 60083</p> <p>Contact: Henry Dudzick (847) 223-3710</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Lake Zurich #3 1 N. Rand Road Lake Zurich, IL 60047</p> <p>Contact: Lisa Railton (847) 223-3710</p>
---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 8,000, (TK # 2, 3) - 6,000, (TK # 6) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2, 3, 6) Piping - Flexible Double Wall NUPI Smartflex, (TK # 1, 2, 3, 6) Piping - Single Wall STP/Tanktop Sump, (TK # 1, 2, 3, 6) Piping - Single Wall Transition Sump*
- (d) Product to be stored in each tank: (TK # 1, 2) - Gasoline - Regular, (TK # 3) - Diesel Fuel, (TK # 6) - Gasoline - Premium*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping: (TK # 1, 2, 3, 6) Corrosion Prot - Piping - Sacrificial Anode Flex Connector*
- (g) Spill containment devices, piping, and dispenser containment devices: (TK # 1, 2, 3, 6) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 1, 2, 3, 6) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Installing new swfrp STP sumps on all existing tanks. Installing Nupi Smartflex DW piping from new STP sumps where a transition sump will be installed to facilitate the connecting of new Nupi piping to the existing dwfrp piping


Replaced piping exceeds 20 feet or 50% of the total pipe run.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Performance Tank, Inc.
730 Creel Drive
Wood Dale, IL 60191

Contact Person: Tim Berg
Phone: (630) 860-9500
Contractor Registration # IL881 Exp. 12/8/2022

Sincerely,



Daniel S. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File