



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 3127453162

<p>FOR OFFICE USE ONLY</p> <p>Facility # 2036929 Permit # 00856-2021UPG Request Rec'd 07/15/2021 Amended Date Approval Date 7/27/2021 Permit Expires 1/27/2022</p>
--

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>City of Chicago Department of Fleet and Facility Management 30 North LaSalle Street, Suite 300 Chicago, IL 60602</p> <p>Contact: Curtis Anderson (312) 747-4950</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>FS003 Northwest 4233 W. Ferdinand St. Chicago, IL 60624</p> <p>Contact: Curtis Anderson (312) 744-8174</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3, 4) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2, 3, 4) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX*
- (d) Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - E-85, (TK # 3, 4) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices: (TK # 1, 2, 3, 4) Spill Contain Device - Double Wall Spill Bucket*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replaced piping exceeds 20 feet or 50% of the total pipe run.

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>K-Plus Mechanical, Inc. 10220 Bode Street Suite A Plainfield, IL 605851631</p>	<p>Contact Person: Gerald Ford Phone: (815) 230-3040 Contractor Registration # IL002335 Exp. 2/9/2022</p>
--	---

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File