



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2009646
Permit # 00941-2021UPG
Request Rec'd 08/10/2021
Amended Date
Approval Date 8/17/2021 DS
Permit Expires 2/17/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>SamJ Properties, Inc. 312 E. Jefferson Street Shorewood, IL 60404</p> <p>Contact: Mathew Thomas (773) 882-2255</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>SamJ, Inc. d/b/aq Samj BP 312 E. Jefferson Street Shorewood, IL 60431</p> <p>Contact: Mathew Thomas (773) 882-2255</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 6, 7, 8, 11) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 6, 7, 8, 11) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L, (TK # 11) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC, (TK # 11) Piping - Ball Valves, (TK # 11) Piping - Shear Valves, (TK # 11) Piping - Flex Connector Steel, (TK # 11) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 6, 8) - Gasoline - Regular, (TK # 7) - Gasoline - Premium, (TK # 11) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 11) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

All gasoline islands and dispensers will remain, except the center island of the rear canopy which will be rebuilt into a diesel island. Three diesel islands will be added North of the rebuilt diesel island. A canopy will be added over the new diesel islands. New double wall flexible piping will be installed to the new islands from the rebuilt island where the existing single wall fiberglass diesel pipe will be picked up in the rebuilt island dispenser sump. A new pump sump will be added for the diesel tank and the existing singlewall piping will be run back into the sump.


NOTE: All dispensers must meet the minimum 10' setback from all buildings and property lines

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: (708) 474-3344
Contractor Registration # IL1207 Exp. 2/14/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File