



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 6040475
Permit # 00961-2021UPG
Request Rec'd 08/17/2021
Amended Date
Approval Date 8/23/2021 DS
Permit Expires 2/23/2022

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Knapp Oil Company, Inc. P.O. Box 215 Xenia, IL 62899</p> <p>Contact: Nicholas Knapp (618) 678-2211</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Nashville Citgo 17970 Mockingbird Road Nashville, IL 62263</p> <p>Contact: Patricia Bailey (618) 678-2211</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 20,000, (TK # 2) - 16,000, (TK # 3) - 4,000, (TK # 4) - 15,000, (TK # 5) - 5,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 1) - B-11, (TK # 2) - Gasoline - Regular, (TK # 3) - Kerosene, (TK # 4) - B-20, (TK # 5) - Gasoline - Premium*
- (e) Type of leak detection being used:*  

*Tank: (TK # 1, 2, 3, 4, 5) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD*

*Piping:*
- (f) Corrosion Protection being used:*  

*Tank:*

*Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

**(4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Removed the Auto Stick system and installed a Veeder Root TLS 450 plus with CSLD. Installed all new probes in all the tanks. Site is still using existing mechanical leak detectors and existing sump sensors.


**NOTE: This permit does not address all of the violations on the N.O.V.'s**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>
---

Mid-South Steel Products, Inc.  
2071 Corporate Circle Drive PO Box 277  
Cape Girardeau, MO 63703

Contact Person: Billy Thorne  
Phone: (573) 335-5529  
Contractor Registration # IL1194 Exp. 8/17/2022

Sincerely,



Daniel H. Starks

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File