



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6009507
Permit # 00977-2021UPG
Request Rec'd 08/26/2021
Amended Date
Approval Date 8/26/2021 DS
Permit Expires 2/28/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Orchard Shell Service, LLC 1900 Vandalia Eagan, IL 62234 Contact: Steve Seuss (618) 345-1827	(2) FACILITY - name and address where tanks are located: Orchard Shell Service, LLC 1900 North Vandalia Collinsville, IL 62234 Contact: Steve Seuss (618) 345-1827
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 6) - 10,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 6) Piping - Fiberglass Single Wall Piping Ameron*

(d) *Product to be stored in each tank: (TK # 6) - Gasoline - Regular*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Piping failed Precision line test, Helium test pinpointed leak location, Excavation and repair to line to be made.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Superior Acquisition LLC d/b/a Superior Equipment Company
7525-A Sussex
St. Louis, MO 63143

Contact Person: Matt Gross
Phone: (314) 644-6000
Contractor Registration # IL002394 Exp. 3/8/2023

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File