



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3006089
Permit # 00979-2021REM
Request Rec'd 08/26/2021
Amended Date
Approval Date 8/26/2021 DS
Permit Expires 2/28/2022

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Mac's Convenience Stores, LLC 550 Warrenville Rd., Suite 400 Lisle, IL 60532</p> <p>Contact: Ralitsa Valkanova (919) 986-6149</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Mac's #1233 877 East Main Street Galesburg, IL 61401</p> <p>Contact: Linc Garcia (217) 243-1838</p>
--	--

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed: (TK # 7, 8, 9) - 12,000, (TK # 10) - 8,000*
- (b) Description/location of piping being removed:*
- (c) Product to be stored in each tank: (TK # 7) - Gasoline - Regular, (TK # 8) - Gasoline - Mid-grade, (TK # 9) - Gasoline - Premium, (TK # 10) - Diesel Fuel*
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used: (TK # 7, 8, 9, 10) - Unknown*

- (4)** The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

1. Site has five (5) dispensers. With new pipe installation all five (5) pumps will be removed at the same time.
2. Site has Total Containment blue poly UDC sumps. All these poly sumps will get removed and FRP sumps will be installed. Pipe is rigid between the shear valve and product trunk line. Site will now need sump sensors. All four (4) STP sumps (FRP) and dispenser sump #1/2 already have sump sensors.
3. Remove the five (5) dispensers from the island and set aside for re-use.
4. Blow the fuel out of the lines and back into the tanks.
5. Remove all of the existing Total Containment pipe from the existing chase pipe, cut into pieces and discard.
6. Furnish and pull in new flex piping with required fittings.
7. Air test all piping
8. Saw cut around existing islands, and 5' x 5' area's on both sides of the island, demo, load and dispose of the concrete.
9. Hand dig to expose the secondary line and conduits entering and leaving the sumps.
10. Cut the conduits back a few feet from the sump and bent the secondary and primary flex piping out of the way.
11. Remove the existing poly sump and set a new fiberglass sump 1.5" higher than existing grade.
12. Install all new bulkhead product fittings onto the sump and reinstall the product lines back into the sumps.
- 12a. PER ILOFSM RULES, with new UDC's the conduits CANNOT be ran back into the sumps. Proposal is to extend the existing conduits to the side of the sumps and thru the existing conduits pull in all new wire (wires will not be long enough now as the conduits have been lengthened. Based on wires being extractable).
13. Install new flex hoses and shear valves.

14. Water test the UDC's

15. Remove the existing bulkheads within all four (4) STP sumps. The STP sumps are already FRP

NOTE: This permit is NOT for the removal of tanks

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File