



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 4011245  
Permit # 01015-2021UPG  
Request Rec'd 09/07/2021  
Amended Date  
Approval Date 9/7/2021 DS  
Permit Expires 3/9/2022

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Love's Travel Stops &amp; Country Stores, Inc. P.O. Box 26210 10601 N. Penn Oklahoma City, OK 73120  Contact: Jerrod Marsh (405) 834-0311</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Love's Travel Stop 750 17919 Newtown Road P.O. Box 399 Oakwood, IL 61858  Contact: Keith Twitty 2173542181</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 18, 20, 22, 24) - 2,000, (TK # 19, 21) - 8,000, (TK # 23) - 7,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 18, 19, 20, 21, 22, 24) - Motor Oil, (TK # 23) - Used Oil*

(e) *Type of leak detection being used:*

*Tank:*

*Piping: (TK # 18, 19, 20, 21, 22, 23, 24) Leak Detect - Piping - Piping Sump Sensors Not Regulated*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

This site has come up for sump testing. The transition sumps have sump sensors and interstitial monitoring is being used for line leak detection. The lines associated with this system are European suction and therefore should be exempt from the testing. I selected non-disrimtating sensors as equipment to be installed for all tanks to allow me to get to this point on the permit application. There are already sensors installed and we would like to simply change the status of the sensors to that of non-regulated status because of the European suction classification. We will not be installing any new sensors. Love's would like to keep the sensors for extra protection but change the status to non-regulated to avoid unnecessary testing.

Thank you

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Illinois Oil Marketing Equipment, Inc.  
850 Brenkman Drive  
Pekin, IL 61554

Contact Person: Chris Epkins  
Phone: (309) 347-1819  
Contractor Registration # IL1293 Exp. 2/4/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File