



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 7040023
Permit # 01056-2021UPG
Request Rec'd 09/14/2021
Amended Date
Approval Date 9/14/2021 DS
Permit Expires 3/15/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Fill Up Mart, Inc. 111 Washington Ave. Cairo, IL 62914</p> <p>Contact: Doris Hodges (618) 734-1491</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Fill-Up Mart 27009 State Hwy. 3 Olive Branch, IL 62969</p> <p>Contact: Patricia Knupp (618) 776-6186</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 3) - 3,000

(b) Type of tanks:

(c) Type of piping: (TK # 3) Piping - Other Steel Riser

(d) Product to be stored in each tank: (TK # 3) - Diesel Fuel

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containment devices: (TK # 3) Spill Contain Device - Single Wall Spill Bucket

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES : 5. Furnish and install two (2) 4" pipe risers for ATG tank probe and spill bucket.

6. Furnish and install one (1) OPW Edge One, single wall, cast iron cover spill bucket for diesel.

7. Furnish and install one (1) 18" manhole for ATG tank probe.

8. Re-install drop tube, adapter, and fill cap to new spill bucket.

9. Re-install diesel tank probe.

10. Backfill, drill and pin to existing concrete and pour new concrete to grad

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: Jimmy Spiros

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2022

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File