



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Revised

<p align="center">FOR OFFICE USE ONLY</p> <p>Facility # 3045322 Permit # 01006-2021UPG Request Rec'd 09/01/2021 Amended Date Approval Date 9/2/2021 DS Permit Expires 3/2/2022</p>

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Metrolink 1515 River Drive Moline, IL 61265 Contact: Chelsey Hohensee (309) 786-3081</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Metrolink 4501 4th Ave. Rock Island, IL 61201 Contact: Luke Hansen (309) 786-3081</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 2) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices: (TK # 2) Spill Contain Device - Double Wall Spill Bucket*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*


(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Revision Reason: Changed tank from 1 to tank 2

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Pipeco, Inc. 610 29TH ST Bettendorf, IA 52722</p>	<p>Contact Person: Debbie Rindler Phone: (563) 344-0700 Contractor Registration # IL2034 Exp. 9/28/2022</p>

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File