



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 5013130
Permit # 01063-2021CAT
Request Rec'd 09/15/2021
Amended Date
Approval Date 9/15/2021 DS
Permit Expires 3/15/2022

Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Road Ranger, LLC 1501 Woodfield Rd., Suite 300 S Schaumburg IL 60173 Contact: John Carabelli (815) 387-1700	(2) <u>FACILITY</u> - name and address where tanks are located: Road Ranger #118 3752 Camp Butler Road Springfield, IL 62707 Contact: John Carabelli (815) 387-1700
---	---

(3) UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

(a) Number and size of tanks having cathodic protection installed, upgraded, or repaired: (TK # 1) - 6,000, (TK # 2, 3, 4, 5) - 8,000, (TK # 8) - 20,000

(b) Type of tanks:

(c) Type of piping:

(d) Product to be stored in each tank: (TK # 1) - Gasoline - Premium, (TK # 2, 5) - Gasoline - Regular, (TK # 3, 4, 8) - Diesel Fuel

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank: (TK # 1) Corrosion Prot - Tank - Sacrificial Anode Cathodic Protection

Piping: (TK # 2, 3, 4, 5, 8) Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection

(g) NACE certified designer:

(h) Method of integrity assessment of tank(s) being used:

(4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling 2177851020.

(5) SPECIAL CONTINGENCIES : Testing all anodes at this site with permit to cover any if bad ones found. adding anode on dispenser #24 for tanks 3,4,6,8, all diesel.

(6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(7) PERSON, FIRM OR COMPANY PERFORMING WORK:

WJ Scott Company
3861 Tozer Road


Contact Person: Jim Scott

Springfield, IL 62707

Phone: (217) 787-6081

Contractor Registration # IL1949 Exp. 4/18/2022

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File