



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 6-003046  
Permit # 01560-2007INS  
Request Rec'd 09/26/2007  
Amended Date  
Approval Date 9/27/2007 JC  
Permit Expires 3/27/2008

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  W.D., Inc. 2605 College Ave. Alton, IL 62002  Contact:	<b>(2) FACILITY</b> - name and address where tanks are located:  Quick Stop 2605 College Avenue Alton, Madison Co., IL  Contact: D V Patel (618) 465-5011
---	---

**(3) INSTALLATION OF TANKS:**

- (a) Number and size of tanks being installed:** (TK # 8) - 10,000 gallons, (TK # 9, 10) - 5,000 gallons
- (b) Type of tanks:** One compartment tank consisting of (TK # 8, 9, 10) - (Installing) Glasteel single wall composite
- (c) Type of piping:** (TK # 8, 9, 10) - (Installing) partial OPW Pisces double wall flexible from new tanks to new transition sump where the piping will connect to the existing piping from the old tank system, (TK # 8, 9, 10) - Existing single wall fiberglass from the existing dispensers to the new transition sump, (TK # 8, 9, 10) - (Installing) OPW Geoduct non-corrosive flexible secondary chase piping for the new piping runs from tanks to the new transition sump. New vent lines will also be installed for these new tanks.
- (d) Product to be stored in each tank:** (TK # 8, 9, 10) - Gasoline
- (e) Type of leak detection being used:**
  - Tank:** (TK # 8, 9, 10) - (Installing) Veeder Root TLS300i automatic tank gauge
  - Piping:** (TK # 8, 9, 10) - (Installing) Veeder Root TLS300i interstitial piping sump sensor at submersible sumps only (TK # 8, 9, 10) - (Installing) Red Jacket FX1DV mechanical line leak detector
- (f) Corrosion Protection being used:**
  - Tank:** (TK # 8, 9, 10) - (Installing) composite
  - Piping:** (TK # 8, 9, 10) - Existing partial fiberglass, (TK # 8, 9, 10) - (Installing) partial Non-corrosive flexible, (TK # 8, 9, 10) - (Installing) partial Fiberglass secondary containment
- (g) Spill containment devices:**
- (h) Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) GENERAL REQUIREMENTS:**

**(6) SPECIAL CONTINGENCIES:**

<b>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b>          Contact Person: Greg Phone:  Contractor Registration # IL-1910 Exp.
--

Sincerely,

