



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
3127453162

Amended

FOR OFFICE USE ONLY

Facility # 2047313
Permit # 01074-2021REM
Request Rec'd 09/17/2021
Amended Date 09/27/2021 Chi
Approval Date 9/20/2021
Permit Expires 3/22/2022

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Amazon.com Services, LLC 410 Terry Ave. N Seattle, WA 98109 Contact: Asher Cousin (832) 405-9656	(2) <u>FACILITY</u> - name and address where tanks are located: Amazon DLN5 Last Mile Delivery Station 4500 W. Division Chicago, IL 60651 Contact: Jeff Cali (847) 243-4300
--	---

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed: (TK # 1) - 10,000, (TK # 2, 3) - 12,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1, 2, 3) - Heating Oil*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 1, 2, 3) - 12/31/1973*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :


Amendment Reason: Additional tanks found

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

RW Collins Company
7225 West 66th Street
Chicago, IL 60638

Contact Person: Lisa Kruse
Phone: (708) 458-6868
Contractor Registration # IL772 Exp. 2/9/2022

Sincerely,


Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File