



Office of the Illinois State Fire Marshal  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 2177851020

<p><b>FOR OFFICE USE ONLY</b>          Facility # 1020390          Permit # 01111-2021INS          Request Rec'd 09/09/2021          Amended Date          Approval Date 9/28/2021 DS          Permit Expires 3/29/2022</p>
---

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:           Kwik Trip, Inc.          P.O. Box 2107          La Crosse, WI 54602           Contact: Troy Batzel (608) 793-6283</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:           Kwik Star 1531          1100 East River Road          Dixon, IL 61021           Contact: Troy Batzel (608) 793-6283</p>
--	--

**(3) INSTALLATION OF TANKS:**

- (a) Number and size of tanks being installed: (TK # 5) - 12,000, (TK # 6, 7) - 6,000*
- (b) Type of tank(s): (TK # 5, 6, 7) Tank - Steel Double Wall Highland Tank Titan Jacketed*
- (c) Type of piping: (TK # 5, 6, 7) Piping - Flexible Double Wall A.P.T. Poly Tech from tanks to dispensers as shown in site plan, (TK # 5, 6, 7) Piping - Extractor Fitting Valves, (TK # 5, 6, 7) Piping - Shear Valves, (TK # 5, 6, 7) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 5) - Gasoline - Regular, (TK # 6) - E-15, (TK # 7) - Gasoline - Premium*
- (e) Type of leak detection being used:*
  - Tank: (TK # 5, 6, 7) Leak Detect - Tank - Automatic Tank Gauging Incon EVO 5000, (TK # 5, 6, 7) Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors*
  - Piping: (TK # 5, 6, 7) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 5, 6, 7) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in submersible and dispenser sumps*
- (f) Corrosion Protection being used:*
  - Tank: (TK # 5, 6, 7) Corrosion Prot - Tank - Jacketed Steel Non-Corrosive*
  - Piping: (TK # 5, 6, 7) Corrosion Prot - Piping - Flexible Non-Corrosive*
- (g) Spill containment devices, piping and dispenser containment devices: (TK # 5, 6, 7) Spill Contain Device - Double Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 5, 6, 7) Overfill Prev Device - Overfill Drop Tube Valve, (TK # 5, 6, 7) Overfill Prev Device - Overfill Alarm*

**(4)** The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) by calling (217)785-1020.

**(5) GENERAL REQUIREMENTS :** There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) **SPECIAL CONTINGENCIES :**


Installing new tanks, piping, leak detection and dispensers. New formed concrete islands to be installed. Existing canopy to remain. Used Gilbarco Encore dispensers to be installed.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Oil Equipment Company, Inc.  
4701 Lien Road  
Madison, WI 53704

Contact Person: TJ Winkler  
Phone: (608) 249-2881  
Contractor Registration # IL1318 Exp. 11/13/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in black ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File