



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 3-013034
Permit # 01511-2007INS
Request Rec'd 09/17/2007
Amended Date
Approval Date 9/19/2007 JC
Permit Expires 3/19/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Jaswal Properties, Inc. 1984 Bluemist Drive Aurora, IL 60504-4824 Contact:	(2) FACILITY - name and address where tanks are located: Jaswal, Inc. 229 N. Canal Street Annawan, Henry Co., IL Contact: Bob Becker (815) 875-6451
--	--

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed:** (TK # 6) - 12,000 gallons, (TK # 7, 8) - 6,000 gallons, (TK # 9) - 2,000 gallons
- (b) Type of tanks:** (TK # 6, 7, 8, 9) - (Installing) XERXES single wall fiberglass
- (c) Type of piping:** (TK # 6, 7, 8, 9) - (Installing) partial A.P.T. Poly Tech P175 SC double wall flexible that will connect to the existing piping via new transition sumps (see site plan), (TK # 6, 7, 8, 9) - Existing non-corrosive flexible to be re-used.
- (d) Product to be stored in each tank:** (TK # 6, 7, 9) - Gasoline, (TK # 8) - Diesel Fuel
- (e) Type of leak detection being used:**
 - Tank:** (TK # 6, 7, 8, 9) - Existing automatic tank gauging to be re-used from old system
 - Piping:** (TK # 6, 7, 8, 9) - Existing line leak detector to be re-used from old system, (TK # 6, 7, 8, 9) - (Installing) Incon TSP ULS Interstitial Sensor at the two new transition sumps only.
- (f) Corrosion Protection being used:**
 - Tank:** (TK # 6, 7, 8, 9) - (Installing) Fiberglass
 - Piping:** (TK # 6, 7, 8, 9) - Existing partial non-corrosive flexible, (TK # 6, 7, 8, 9) - (Installing) partial Non-corrosive flexible
- (g) Spill containment devices:**
- (h) Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

(7) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Rob Vyncke Phone: Contractor Registration # Exp.
--

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)