



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<u>FOR OFFICE USE ONLY</u>
Facility # 2-043805
Permit # 01507-2007REM
Request Rec'd 09/18/2007
Amended Date
Approval Date 9/18/2007 JC
Permit Expires 3/18/2008

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Clarke Construction, LLC          1937 West Fulton Street          Chicago, IL 60612          Contact: Michael Clarke (312) 491-0600</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Clarke Construciton, LLC          9601 South Pulaski Avenue          Evergreen Park, Cook Co., IL          Contact: Michael Clarke (312) 491-0600</p>
--	---

**(3) REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed:* (TK # 1, 2, 3) - 6,000 gallons
- (b) *Product stored in each tank:* (TK # 1, 2, 3) - Gasoline
- (c) *Reason of tanks being removed:*
- (d) *If tank(s) is leaking, indicate IEMA incident number:*
- (e) *Date each tank was last used:* (TK # 1, 2, 3) - 12/31/1973

**(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form This form can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 170.640 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.**

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>          Pioneer Engineering &amp; Environmental          700 N. Sacramento Blvd., #101</p>	<p>Contact Person: Troy Woodtke          Phone:          Contractor Registration #    Exp.</p>
--	--

Sincerely,

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 6/07)