



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

<p align="center">FOR OFFICE USE ONLY</p> <p>Facility # 4010806 Permit # 00650-2021UPG Request Rec'd 05/24/2021 Amended Date 10/07/2021 DS Approval Date 6/1/2021 DS Permit Expires 12/1/2021</p>
--

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>South Central FS, Inc. 405 S. Banker Street P.O. Box 629 Effingham, IL 62401 Contact: Ken Bierman (217) 342-9231</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>South Central FS, Inc. 410 S. Willow Effingham, IL 62401 Contact: Cat Merrill (217) 342-9231</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 16) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 16) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX*
- (d) Product to be stored in each tank: (TK # 16) - B-11*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Amendment Reason: We are needing to amend this permit due to we did not find a flexline leaking on pumps #9 and #10. We found a union and a 6" nipple leaking. We replaced with a new union and a new 6" nipple. A Precision test was conducted on 05/26/2021 and it passed. We are just needing to schedule a final inspection.

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>Pemco Service Company, Inc. 1040 East Second Street</p>	<p>Contact Person: William "Butch" VonDrehle Phone: (815) 265-7364</p>
---	--

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File