



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 4020620
Permit # 00960-2021UPG
Request Rec'd 08/23/2021
Amended Date 10/07/2021 DS
Approval Date 8/23/2021 DS
Permit Expires 2/23/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle (515) 446-6231	(2) <u>FACILITY</u> - name and address where tanks are located: Casey's General Store #2934 1301 S. Main St. Normal, IL 61761 Contact: JR Causey (515) 965-6238
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 5, 6, 7) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 5, 6, 7) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC, (TK # 5, 6, 7) Piping - Ball Valves, (TK # 5, 6, 7) Piping - Extractor Fitting Valves, (TK # 5, 6, 7) Piping - Shear Valves, (TK # 5, 6, 7) Piping - Flex Connector Steel, (TK # 5, 6, 7) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 5) - Gasoline - Regular, (TK # 6) - Diesel Fuel, (TK # 7) - Gasoline - Premium*
- (e) Type of leak detection being used:*
 - Tank: (TK # 5, 6, 7) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD, (TK # 5, 6, 7) Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors*
 - Piping: (TK # 5, 6, 7) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 5, 6, 7) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices: (TK # 5, 6, 7) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 5, 6, 7) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Installing (6) new 3'x 5' island forms with dual U-shaped pipe bollards for collision protection.

Existing canopy to remain.

Installing (6) new Gilbarco Encore 700S dispensers.

Replaced piping exceeds 20 feet or 50% of the total pipe run.


Amendment Reason: Not installing new Veeder Root TLS 450 system. Existing Veeder Root TLS 350 system to remain.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Total Petroleum Service Company
2421 Washington Road
Washington, IL 61571

Contact Person: Greg McCoy
Phone: (309) 694-8224
Contractor Registration # IL1079 Exp. 2/8/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel S. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File